



# ETATRON

engineered excellence

## AG-SELECT MENU GUIDE

FACTORY RESET AG-SELECT B2

# Factory Reset AG-Select B2

1. Power off instrument
2. Power instrument back up
3. Press OK button within 15 seconds
4. After screen has changed hold down the MINUS and PLUS buttons simultaneously
5. "SET DEFAULTS" should be shown on screen, if you do not see "SET DEFAULTS" start again taking extra care on step 4
6. Press PLUS, PLUS, RIGHT ARROW to start a full reset or MINUS, MINUS, RIGHT ARROW for a partial reset

